

COA No:	SYD-51172680-0
Supersedes:	None
COA Date:	17/07/2018
Page 1 of 4	

**TO:**  
 Lalitha Sridhar  
 Suprima Bakeries Pty Ltd  
 1 Magnum Place  
 MINTO, NSW 2566

Received From:	Minto, NSW
Received Date:	05/07/2018
P.O.#:	15164
Location of Test: (except where noted) Regents Park, NSW	

**Analytical Results**

<b>Desc. 1:</b>	Water Sample - Office Hand Wash	<b>Sample Number:</b>	454703133
<b>Desc. 2:</b>	Date Sampled: 05.07.2018	<b>Condition Rec'd:</b>	NORMAL
		<b>Temp Rec'd (°C):</b>	5
		<b>Date Started:</b>	6/07/2018 @ 07:40

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method Reference</u>	<u>Result Date</u>	<u>Loc.</u>
Copper (Cu)	0.166	mg/L	FAB102	17/07/2018	
Iron (Fe)	<0.05	mg/L	FAB102	17/07/2018	
Lead (Pb)	0.003	mg/L	FAB102	17/07/2018	
Zinc (Zn)	0.032	mg/L	FAB102	17/07/2018	
Heterotrophic Colony Count @ 22°C	63	CFU/mL	M11.1	09/07/2018	
Heterotrophic Colony Count @ 36°C	2.0 est.	CFU/mL	M11.1	08/07/2018	
Coliforms	<1	CFU/100mL	M12.1	07/07/2018	
E.coli	<1	CFU/100mL	M12.2	07/07/2018	

<b>Desc. 1:</b>	Water Sample - L1 Hand Wash	<b>Sample Number:</b>	454703136
<b>Desc. 2:</b>	Date Sampled: 05.07.2018	<b>Condition Rec'd:</b>	NORMAL
		<b>Temp Rec'd (°C):</b>	5
		<b>Date Started:</b>	6/07/2018 @ 07:40

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method Reference</u>	<u>Result Date</u>	<u>Loc.</u>
Copper (Cu)	0.179	mg/L	FAB102	17/07/2018	
Iron (Fe)	<0.05	mg/L	FAB102	17/07/2018	
Lead (Pb)	0.002	mg/L	FAB102	17/07/2018	
Zinc (Zn)	0.030	mg/L	FAB102	17/07/2018	
Heterotrophic Colony Count @ 22°C	850	CFU/mL	M11.1	09/07/2018	
Heterotrophic Colony Count @ 36°C	350	CFU/mL	M11.1	08/07/2018	
Coliforms	<1	CFU/100mL	M12.1	07/07/2018	
E.coli	<1	CFU/100mL	M12.2	07/07/2018	



*NATA Corporate Accreditation Number: 2020  
 Melbourne Microbiology Site No: 2013.  
 Sydney Microbiology Site No: 2759, Chemistry Site No: 2135  
 Perth Microbiology Site No: 10635  
 Brisbane Microbiology Site No: 15147  
 Accredited for compliance with ISO/IEC 17025.*

The data pertains solely to the analytical and sampling procedure(s) used and the condition and homogeneity of the sample(s) as received. The data therefore may not be representative of the lot or batch or other samples.

This report shall not be reproduced except in full.  
 Measurement Uncertainty (MU) can be found by logging in to MyMXNS

COA No:	SYD-51172680-0
Supersedes:	None
COA Date:	17/07/2018
Page 2 of 4	

**TO:**  
 Lalitha Sridhar  
 Suprima Bakeries Pty Ltd  
 1 Magnum Place  
 MINTO, NSW 2566

Received From:	Minto, NSW
Received Date:	05/07/2018
P.O.#:	15164
Location of Test: (except where noted) Regents Park, NSW	

**Analytical Results**

<b>Desc. 1:</b>	Water Sample - L2 Hand Wash	<b>Sample Number:</b>	454703137
<b>Desc. 2:</b>	Date Sampled: 05.07.2018	<b>Condition Rec'd:</b>	NORMAL
		<b>Temp Rec'd (°C):</b>	5
		<b>Date Started:</b>	6/07/2018 @ 07:40

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method Reference</u>	<u>Result Date</u>	<u>Loc.</u>
Copper (Cu)	0.135	mg/L	FAB102	17/07/2018	
Iron (Fe)	<0.05	mg/L	FAB102	17/07/2018	
Lead (Pb)	0.001	mg/L	FAB102	17/07/2018	
Zinc (Zn)	0.020	mg/L	FAB102	17/07/2018	
Heterotrophic Colony Count @ 22°C	770	CFU/mL	M11.1	09/07/2018	
Heterotrophic Colony Count @ 36°C	210	CFU/mL	M11.1	08/07/2018	
Coliforms	480 est.	CFU/100mL	M12.1	09/07/2018	
E.coli	<1	CFU/100mL	M12.2	08/07/2018	

<b>Desc. 1:</b>	Water Sample - Wash Bay	<b>Sample Number:</b>	454703138
<b>Desc. 2:</b>	Date Sampled: 05.07.2018	<b>Condition Rec'd:</b>	NORMAL
		<b>Temp Rec'd (°C):</b>	5
		<b>Date Started:</b>	6/07/2018 @ 07:40

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method Reference</u>	<u>Result Date</u>	<u>Loc.</u>
Copper (Cu)	0.122	mg/L	FAB102	17/07/2018	
Iron (Fe)	<0.05	mg/L	FAB102	17/07/2018	
Lead (Pb)	0.004	mg/L	FAB102	17/07/2018	
Zinc (Zn)	0.093	mg/L	FAB102	17/07/2018	
Heterotrophic Colony Count @ 22°C	<1	CFU/mL	M11.1	09/07/2018	
Heterotrophic Colony Count @ 36°C	3.0 est.	CFU/mL	M11.1	08/07/2018	
Coliforms	<1	CFU/100mL	M12.1	07/07/2018	
E.coli	<1	CFU/100mL	M12.2	07/07/2018	



NATA Corporate Accreditation Number: 2020  
 Melbourne Microbiology Site No: 2013.  
 Sydney Microbiology Site No: 2759, Chemistry Site No: 2135  
 Perth Microbiology Site No: 10635  
 Brisbane Microbiology Site No: 15147  
 Accredited for compliance with ISO/IEC 17025.

The data pertains solely to the analytical and sampling procedure(s) used and the condition and homogeneity of the sample(s) as received. The data therefore may not be representative of the lot or batch or other samples.

This report shall not be reproduced except in full.  
 Measurement Uncertainty (MU) can be found by logging in to MyMXNS



COA No:	SYD-51172680-0
Supersedes:	None
COA Date:	17/07/2018
Page 3 of 4	

**TO:**  
 Lalitha Sridhar  
 Suprima Bakeries Pty Ltd  
 1 Magnum Place  
 MINTO, NSW 2566

Received From:	Minto, NSW
Received Date:	05/07/2018
P.O.#:	15164
Location of Test: (except where noted) Regents Park, NSW	

**Analytical Results**

<b>Desc. 1:</b>	Water Sample - Ice Slurry -	<b>Sample Number:</b>	454703140
<b>Desc. 2:</b>	(H2O Ingredient)	<b>Condition Rec'd:</b>	NORMAL
<b>Desc. 3:</b>	Date Sampled: 05.07.2018	<b>Temp Rec'd (°C):</b>	5
		<b>Date Started:</b>	6/07/2018 @ 07:40

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method Reference</u>	<u>Result Date</u>	<u>Loc.</u>
Copper (Cu)	0.044	mg/L	FAB102	17/07/2018	
Iron (Fe)	<0.05	mg/L	FAB102	17/07/2018	
Lead (Pb)	<0.001	mg/L	FAB102	17/07/2018	
Zinc (Zn)	<0.005	mg/L	FAB102	17/07/2018	
Heterotrophic Colony Count @ 22°C	9900	CFU/mL	M11.1	09/07/2018	
Heterotrophic Colony Count @ 36°C	2.0 est.	CFU/mL	M11.1	08/07/2018	
Coliforms	45	CFU/100mL	M12.1	09/07/2018	
E.coli	<1	CFU/100mL	M12.2	08/07/2018	

<b>Desc. 1:</b>	Rinse after 2nd Chemical	<b>Sample Number:</b>	454703147
<b>Desc. 2:</b>	Date Sampled: 05.07.2018	<b>Condition Rec'd:</b>	NORMAL
		<b>Temp Rec'd (°C):</b>	5
		<b>Date Started:</b>	6/07/2018 @ 07:40

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method Reference</u>	<u>Result Date</u>	<u>Loc.</u>
Heterotrophic Colony Count @ 22°C	1500	CFU/mL	M11.1	09/07/2018	
Heterotrophic Colony Count @ 36°C	16	CFU/mL	M11.1	08/07/2018	
Total Mould Count	Unable to determine due to the overgrowth of yeast	CFU/100mL	M4.3	12/07/2018	
Total Yeast Count	>800	CFU/100mL	M4.3	12/07/2018	



*NATA Corporate Accreditation Number: 2020  
 Melbourne Microbiology Site No: 2013.  
 Sydney Microbiology Site No: 2759, Chemistry Site No: 2135  
 Perth Microbiology Site No: 10635  
 Brisbane Microbiology Site No: 15147  
 Accredited for compliance with ISO/IEC 17025.*

The data pertains solely to the analytical and sampling procedure(s) used and the condition and homogeneity of the sample(s) as received. The data therefore may not be representative of the lot or batch or other samples.

This report shall not be reproduced except in full.  
 Measurement Uncertainty (MU) can be found by logging in to MyMXNS